

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA T: **781 762 4300** F: 781-762-9375 www.fmapprovals.com

## **CERTIFICATE OF COMPLIANCE**

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

## 32aaMD+34-bcde0-f-gh. Digital Positioner.

IS/I,II,III/1/ABCDEFG/T4 Ta =  $-52^{\circ}$ C to  $85^{\circ}$ C, T6 Ta =  $-52^{\circ}$ C to  $45^{\circ}$ C; - 346464; Entity; Type 4X, IP65; I/0/Ex ia IIC/T4 Ta =  $-52^{\circ}$ C to  $85^{\circ}$ C, T6 Ta =  $-52^{\circ}$ C to  $45^{\circ}$ C; - 346464; Entity; Type 4X, IP65; NI/I/2/ABCD/ T4 Ta =  $-52^{\circ}$ C to  $85^{\circ}$ C, T6 Ta =  $-52^{\circ}$ C to  $45^{\circ}$ C; Type 4X, IP65; Entity Parameters:

	4-20 Input and Remote Mount HART 4-20 Input	MFC Card	Remote Mount Output	
Ui (V)	30	30	Uo (V)	5
li (mA)	100	100	lo (mA)	79
Pi (mW)	800	800	Po (mW)	129
Ci (nF)	0	0	Co (µF)	2
Li (µH)	47	0	Lo (µH)	100

aa = Diagnostics: 00, 10 or 20

b = Housing: W, S, B or A

c = Conduit Connection: 1 or 2

d = Shaft: V, R or D

e = Action: 1, 2, 3, 4 or 5

f = Pressure Gauge: 0, 1, 2, 3, 4, A or B

g = Auxiliary Card slot 1: 0 or 1

h = Remote Mount: 0, A or S

## Specific Conditions of Use:

1. To avoid possibility of static discharge clean only with a damp cloth.

2. The Digital Positioner enclosure contains aluminum and is considered to present a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction.

3. Provisions shall be made externally to provide transient overvoltage protection to a level not to exceed 140% of the peak rated input voltage.

4. For type nA installation only air or inert gas may be connected to the air supply line.

5. Using the box provided on the nameplate, the User shall permanently mark the type of protection chosen for the specific installation. Once the type of protection has been marked it shall not be changed.

To verify the availability of the Approved product, please refer to <u>www.approvalguide.com</u> FM Approvals HLC 5/13 0003056334C Page 1 of 3



**Equipment Ratings:** 

Intrinsically Safe for Class I, II, III Division 1, Groups A, B, C, D, E, F and G in accordance with drawing 346464; Intrinsically Safe for Class I, Zone 0, Ex ia IIC in accordance with drawing 346464; Nonincendive for Class I, Division 2, Group A, B, C and D hazardous (classified) locations, Type 4X, IP65.

FM Approved for:

Flowserve US Inc Springville, UT United States



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA C22.2 No. 157 CSA C22.2 No. 213 CSA C22.2 No. 60079-0 CSA C22.2 No. 60079-11 CSA C22.2 No. 1010.1 CSA C22.2 No. 60529

Original Project ID: 0003056334

Approval Granted: April 15, 2016

Subsequent Revision Reports / Date Approval Amended Report Number Date Report Number Date

FM Approvals LLC

Marguerdunt

JÆ. Marquedant Manager of Electrical Systems

15 April 2016 Date